



VASUDHA

enviro labs Pvt. Ltd.

H. No 5-9-285/3, 2nd Floor, Rajiv Gandhi Nagar,
Opp. Andhra Jyothi, Prasanthi Nagar,
Kukatpally, Hyderabad - 500072
Phone: +91- 40-40203910 Fax: +91-40-42009193
e-mail: vasudha.enviro@gmail.com,
vasudha@vasudha.in Website: www.vasudha.in

TEST REPORT

CUSTOMER NAME & ADDRESS		TEST REPORT NO.	VMR -0343- 1025
M/s. Epistemo Vikas Leadership School. Aparna Cyber Life. Plot No: B4, Nallagandla Residential Complex, Opp Lane, Huda Layout, Nallagandla, Hyderabad.		REPORT ISSUE DATE	09 th October 2025
		REGISTRATION NO.	VEL/110
		REGISTRATION DATE	06 th October 2025
		CUSTOMER REFERENCE	--
SAMPLE DESCRIPTION	B. RO Water	REFERENCE DATE	--
		ANALYSIS STARTING DATE	06 th October 2025
SAMPLE SITE	--	ANALYSIS COMPLETION DATE	09 th October 2025
		STORAGE CONDITION	0 - 4°C
		CONDITION UPON RECEIPT	Acceptable
QUANTITY RECEIVED		1000 ml	
SAMPLE COLLECTED OR SUBMITTED		By Client	

TEST RESULTS


S.NO	PARAMETERS	UNITS	TEST METHOD	RESULTS	LIMITS
Physical Parameters					
1	pH	--	IS 3025 P - 11	7.01	6.50 - 8.50
2	Conductivity	µs/cm	APHA	80.2	Not Specified
3	Colour	Hazen	IS 3025 P - 04	0.0	< 5
4	Turbidity	NTU	IS 3025 P - 10	0.0	< 1
5	Total Dissolved Solids	mg/l	IS 3025 P - 16	40.1	< 500
Chemical Parameters					
6	Total Alkalinity as CaCO ₃	mg/l	IS 3025 P - 23	80	< 200
7	Total Hardness as CaCO ₃	mg/l	IS 3025 P - 21	88	< 200
8	Calcium as Ca	mg/l	IS 3025 P - 40	17.6	< 75
9	Magnesium as Mg	mg/l	IS 3025 P - 46	10.6	< 30
10	Non carbonate Hardness as CaCO ₃	mg/l	IS 3025 P - 21	8	Not Specified
11	Carbonate Hardness as CaCO ₃	mg/l	IS 3025 P - 21	80	Not Specified
12	Sodium as Na	mg/l	IS 3025 P - 45	1.0	Not Specified
13	Potassium as K	mg/l	IS 3025 P - 45	0.5	Not Specified
14	Fluoride as F	mg/l	IS 3025 P - 60	0.4	< 1.0
15	Chlorides as Cl	mg/l	IS 3025 P - 32	36.8	< 250
16	Sulphates as SO ₄	mg/l	IS 3025 P - 24	2.9	< 200
17	Nitrates as NO ₃	mg/l	IS 3025 P - 34	0.08	< 45
18	Iron as Fe	mg/l	IS 3025 P - 53	0.04	< 0.3
Microbiological parameters					
1	Escherichia coli	Presence	IS 5887 P - 01	Absence	Should be absent
2	Total Coliforms	Presence	IS 5887 P - 01	Absence	Should be absent
3	Total Plate Count	CFU/ml	IS 5402	06	< 100

REMARKS

Note: The result relates to sample tested on 09/10/2025. Results are given as per IS 10500-2012 drinking water specification desirable limits.

Remark: All parameters are within the limits.

shishisha
Chemist



Authorized Signatory

Secretary